



NOMINAL HEIGHT	(A)	(B)
4'-6"	4'-0"	2'-8"
6'-0"	5'-6"	4'-2"
8'-0"	7'-6"	6'-2"

**DESIGNER NOTE**  
(REMOVE PRIOR TO PLOTTING FINAL PLAN):  
CHOOSE ONE HEIGHT FROM RAILING HEIGHT TABLE ABOVE AND CROSS OUT OTHER HEIGHTS. RAIL HEIGHTS GREATER THAN SHOWN REQUIRE REDESIGN.

**DESIGNER NOTE**  
(REMOVE PRIOR TO PLOTTING FINAL PLAN):  
T-4 ORNAMENTAL METAL RAILINGS MOUNTED ON A CURB MUST BE PROTECTED BY A TRAFFIC BARRIER.

**GENERAL NOTES**

CONTINUOUSLY GROUND ALL METAL RAILINGS; SEE THE SPECIAL PROVISIONS. REFER TO THE ELECTRICAL PLANS AND ELECTRICAL SPECIAL PROVISIONS FOR DETAILS REGARDING BONDING MULTIPLE ELECTRICAL GROUNDING SYSTEMS.

PAYMENT LENGTH SHALL BE MEASURED AS THE OUT TO OUT LENGTH ALONG THE CENTERLINE OF THE RAILING BETWEEN THE OUTSIDE ENDS, WITH DEDUCTIONS FOR THE LENGTH OF CONCRETE POSTS, IF PRESENT.

PROVIDE A500, GRADE B STRUCTURAL STEEL TUBING (HSS) IN THE RAIL CONFORMING TO SPEC. 3361. ALL OTHER STEEL SHALL CONFORM TO SPEC. 3306.

GALVANIZE BOLTS, NUTS, WASHERS AND ANCHORS PER SPEC. 3392. GALVANIZE ALL OTHER STRUCTURAL STEEL PER SPEC. 3394, AFTER FABRICATION.

COAT THE GALVANIZED RAILING, BASE PLATES, AND PROTRUDING PORTIONS OF BOLTS, NUTS, ANCHORS, AND WASHERS.

INSTALL RAIL POSTS AND SPINDLES [NORMAL TO GRADE OR PLUMB.]

CURVE HORIZONTAL RAILS WHERE APPLICABLE AND PLACE RAILS PARALLEL TO THE EDGE OF SIDEWALK PROFILE.

SEE SPECIAL PROVISIONS FOR REQUIREMENTS NOT INCLUDED ON THIS SHEET.

DRILL 1/2" DIA. MAX. VENT HOLES ON THE UNDERSIDE OF RAIL TUBES AS NECESSARY TO FACILITATE GALVANIZING.

- ① DRILL VENT HOLE IN THE RAIL POST WITHIN 2" OF THE UNDERSIDE OF THE CAP, ON THE NON-TRAFFIC SIDE OF THE POST AS NECESSARY TO FACILITATE GALVANIZING. MAXIMUM HOLE SIZE IS 1/2" DIA.
- ② SEE SUPERSTRUCTURE SHEETS AND STANDARD FIGURE 5-397.167 FOR CONTROL JOINT SPACING AND DETAILS.
- ③ PROVIDE A PYRAMID TOP STYLE STEEL CAP WELDED TO TOP OF POST WITH A SURFACE FINISH OF 1000 MICRO-INCH, OR SMOOTHER, PRIOR TO GALVANIZING.
- ④ ADHESIVE ANCHORAGE WITH 5/8" DIA. ANCHOR ROD PER SPEC. 3385, TYPE A WITH HEX NUT AND WASHER. PROVIDE AN ADHESIVE WITH A MINIMUM CHARACTERISTIC BOND STRENGTH IN UNCRACKED CONCRETE OF 1.5 KSI. EMBED THE ANCHORAGE NO LESS THAN 8" REGARDLESS OF CHARACTERISTIC BOND STRENGTH. DRILL THROUGH REINFORCEMENT (IF ENCOUNTERED) TO ACHIEVE MINIMUM EMBEDMENT. ENSURE HEX NUT IS IN CONTACT WITH THE ADJACENT SURFACE AND TORQUE TO 60 FT-LBS UNLESS A HIGHER TORQUE IS RECOMMENDED BY THE MANUFACTURER. PROOF LOAD TO 8.8 KIPS. SEE SPECIAL PROVISIONS FOR ADDITIONAL REQUIREMENTS.

**DESIGNER NOTE**  
(REMOVE PRIOR TO PLOTTING FINAL PLAN):  
DESIGNER SHALL CONSULT WITH BRIDGE OFFICE ARCHITECTURAL SPECIALIST. CHANGE NOTE ACCORDINGLY.

REVISION: 05-25-2016

APPROVED: NOVEMBER 6, 2013

*Nancy Subenberger*  
STATE BRIDGE ENGINEER

CERTIFIED BY \_\_\_\_\_ DATE \_\_\_\_\_  
LICENSED PROFESSIONAL ENGINEER

NAME: \_\_\_\_\_ LIC. NO. \_\_\_\_\_

TITLE: ORNAMENTAL METAL RAILING (DESIGN T-4 CURB MOUNT)

DES: \_\_\_\_\_ DR: \_\_\_\_\_ APPROVED: \_\_\_\_\_  
CHK: \_\_\_\_\_ CHK: \_\_\_\_\_ MODIFIED

SHEET NO. OF SHEETS

BRIDGE NO. \_\_\_\_\_

FIG. 5-397.163